
33,945.+
001
33,945.◊
33,945.÷
30.=
1,131.5*
1,131.5×
10.%
113.15*
113.15+
1,244.65*

AN 6/E.

MR-1

PRETREATMENT MONITORING REPORT

NAME: HEXCEL CORPORATION

MAILING ADDRESS 11711 DUBLIN BLVD, DUBLIN, CA 94568-2832

FACILITY LOCATION: 205 MAIN STREET, LODI, NEW JERSEY 07644

CATEGORY & SUBPART: UNKNOWN OUTLET #: 1

CONTACT OFFICIAL: A. WILLIAM NOSIL TELEPHONE #: 925-551-4900

NEW CUSTOMER ID/ OUTLET ID: 17630001-1 OLD OUTLET DESIGNATION: _____

MONITORING PERIOD					
6	1	2008	6	30	2008
MO.	DAY	YR	MO.	DAY	YR.
START			END		

For Reporting Period

	Average	Maximum
Regulated Flow-gal/day	1132	
Total Flow-gal/day	1132	1244

Method used: Total flow divided by 30 days.

Production rate (if applicable):

PARAMETER		MASS LIMIT OR CONCENTRATION			# OF SAMPLES	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS		COMP/GRAB
Cadmium	**Sample Measurement**	< 0.0004		MG/L	1	COMP
	Permit Requirement	0.19		MG/L		
Copper	**Sample Measurement**	0.0399		MG/L	1	COMP
	Permit Requirement	3.02		MG/L		
Lead	**Sample Measurement**	0.0058		MG/L	1	COMP
	Permit Requirement	0.54		MG/L		
Mercury	**Sample Measurement**	< 0.0001		MG/L	1	COMP
	Permit Requirement	0.080		MG/L		
Nickel	**Sample Measurement**	0.0058		MG/L	1	COMP
	Permit Requirement	5.9		MG/L		
Zinc	**Sample Measurement**	0.0342		MG/L	1	COMP
	Permit Requirement	1.67		MG/L		
Petroleum Hydrocarbons	**Sample Measurement**		< 5	MG/L	1	GRAB
	Permit Requirement		100	MG/L		
VOC FOR 413.4	**Sample Measurement**		0.0181	MG/L	1	GRAB
	Permit Requirement		2.13	MG/L		
BOD	**Sample Measurement**	6.6		MG/L	1	COMP
	Permit Requirement			MG/L		

PVSC Form MR-1 Rev: 4 6/87 P1

Certification of Non-use if applicable (use additional sheets): _____

Compliance or non compliance statement with compliance schedule (use additional sheets if necessary) for every parameter used: All parameters were in compliance with the applicable limits.

Explain Method for preserving samples: All samples were preserved with ice. In addition the VOC samples were preserved with HCl, the Metals sample was preserved with HNO_3, and the PHC sample was preserved with HCl.

I certify under penalty of law that this document and attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

403.6(a)(2)(ii) revised by 53 FR 40610, October 17, 1988

Sean Clifford

Signature of Principal
Executive or Authorized Agent

Sean Clifford, as agent on behalf of Hexcel Corporation
Type Name and Title

7/14/8

Date

PVSC Form MR-1 Rev: 5 3/91 P2

Client ID: **LSP-701-060508**
Site: Hexcel PVSC

Lab Sample No: **925045**
Lab Job No: V316

Date Sampled: 06/05/08
Date Received: 06/05/08
Date Analyzed: 06/09/08
GC Column: Rtx-VMS
Instrument ID: VOAMS11.i
Lab File ID: n46023.d

Matrix: WATER
Level: LOW
Purge Volume: 5.0 ml
Dilution Factor: 1.0

VOLATILE ORGANICS - GC/MS
METHOD 624

Parameter	Analytical Result Units: ug/l	Method Detection Limit Units: ug/l
Chloromethane	ND	0.4
Bromomethane	ND	0.4
Vinyl Chloride	ND	0.2
Chloroethane	ND	0.4
Methylene Chloride	7.2	0.4
Trichlorofluoromethane	ND	0.4
1,1-Dichloroethene	ND	0.5
1,1-Dichloroethane	ND	0.3
trans-1,2-Dichloroethene	ND	0.4
cis-1,2-Dichloroethene	2.3	0.3
Chloroform	6.4	0.2
1,2-Dichloroethane	ND	0.3
1,1,1-Trichloroethane	ND	0.4
Carbon Tetrachloride	ND	0.3
Bromodichloromethane	1.2	0.2
1,2-Dichloropropane	ND	0.5
cis-1,3-Dichloropropene	ND	0.1
Trichloroethene	ND	0.4
Dibromochloromethane	0.4	0.3
1,1,2-Trichloroethane	ND	0.2
Benzene	ND	0.2
trans-1,3-Dichloropropene	ND	0.2
2-Chloroethyl Vinyl Ether	ND	0.2
Bromoform	ND	0.2
Tetrachloroethene	0.6	0.4
1,1,2,2-Tetrachloroethane	ND	0.4
Toluene	ND	0.3
Chlorobenzene	ND	0.2
Ethylbenzene	ND	0.4
Xylene (Total)	ND	0.4
1,3-Dichlorobenzene	ND	0.4
1,4-Dichlorobenzene	ND	0.4
1,2-Dichlorobenzene	ND	0.5
Naphthalene	ND	0.5

Client ID: **LSP-701-060508**
Site: **Hexcel PVSC**

Lab Sample No: 925045
Lab Job No: V316

Date Sampled: 06/05/08
Date Received: 06/05/08

Matrix: WATER
Level: LOW

METALS ANALYSIS

Analyte	Analytical Result Units: ug/l	Instrument Detection Limit	Qual	M
Cadmium	ND	0.40		P
Copper	39.9	3.7		P
Lead	5.8	2.7		P
Mercury	ND	0.10		CV
Nickel	5.8	2.4	B	P
Zinc	34.2	5.8		P

Qual Column - Data Reporting Qualifiers (See Sec 2 of Report)
M Column - Method Code (See Section 2 of Report)

TestAmerica Edison
TestAmerica Edison
Wet Chemistry Analysis

Client Sample No.

LSP-701-060508

Lab Name: TestAmerica Laboratories Inc. Contract: NO

Lab Code: RECNY Case No.: _____ SAS No.: _____ SDG No.: V316

Matrix (soil/water): WATER Lab Sample ID: A8654101

% Solids: 0.0 Date Samp/Recv: 06/05/2008 06/07/2008

Parameter Name	Units of Measure	Result	C	Q	M	Method Number	Analyzed Date
SGT Total Petroleum Hydrocarbons	MG/L	5.0	U			1664 SGT	06/09/2008

Comments:

General Information

Chain of Custody

TestAmerica Edison
777 New Durham Road
Edison, New Jersey 08817
Phone: (732) 549-3900 Fax: (732) 549-3679

1° IR 08

CHAIN OF CUSTODY / ANALYSIS REQUEST

Name (for report and invoice): Nagi Alla	Samplers Name (Printed): Nagi Alla	Site/Project Identification: Hexcel - PVSC
Company: Haley & Aldrich	P.O. #: 35119-010-1	State (Location of site): NJ: X NY: Other:
Address: 299 Cherry Hill Road	Analysis Turnaround Time: Standard ☐	Regulatory Program:
City: Parsippany State: NJ 07054	Rush Charges Authorized For: 2 Week ☐ 1 Week ☐ Other ☒ 3 day	LAB USE ONLY Project No: 921674
Phone: 201-841-2429 Fax: 973-658-3961		Job No: V 316

Sample Identification	Date	Time	Matrix	No. of Cont.	pp-VOA+10	BOD	TPH	metals list (Cd, Cu, Hg, Ni, Pb, Zn)	Sample Numbers
LSP-701-060508	6/5/2008	1040	AQ	6	x	x	x	x	925045
City Water-060508	6/5/2008	1042	AQ	1				x	925046
Preservation Used: 1 = ICE, 2 = HCl, 3 = H_2SO_4, 4 = HNO_3, 5 = NaOH 6 = Other _____, 7 = Other _____				Soil:					
				Water:	1,2	1	1,2	1,4	

Special Instructions

Water Metals Filtered (Yes/No)? _____

Relinquished by: Nagi Alla	Company: Haley & Aldrich, Inc.	Date / Time: 6/6/08 1345	Received by 1): Jusha Smith	Company: TestAmerica
Relinquished by 2): Jusha Smith	Company: TestAmerica	Date / Time: 6/6/08 1630	Received by 2):	Company: Test America
Relinquished by 3):	Company:	Date / Time:	Received by 3):	Company:
Relinquished by 4):	Company:	Date / Time:	Received by 4):	Company:

Laboratory Certifications: New Jersey (12028), New York (11452), Pennsylvania (68-522), Connecticut (PH-0200), Rhode Island (132).

North Carolina (No. 578)

Haley & Aldrich
299 Cherry Hill Rd.
Suite 105
Parsippany, NJ 07054-1124

Tel: 973.263.3900
Fax: 973.263.2580
HaleyAldrich.com

HALEY& ALDRICH

16 July 2008
File No. 35119-021

Passaic Valley Sewerage Commissioners
Industrial Department
600 Wilson Avenue
Newark, New Jersey 07105

Attention: Angela Dees
Senior Industrial Technician

Subject: Discharge Monitoring Report for the Month of June 2008
Hexcel Facility
205 Main Street
Lodi, New Jersey
New Customer ID/ Outlet ID: 17630001-1

Dear Ms. Dees:

On behalf of Hexcel Corporation (Hexcel), we provide the enclosed Discharge Monitoring Report (DMR) for discharge of scrubber blow down from the groundwater treatment system at the above-referenced facility. The discharge met all applicable permit limitations, as indicated in the enclosed DMRs.

Please note that the effluent flow totalizer meter was replaced on 30 June 2008. The replacement meter was of the same type and manufacturer as the original. The meter reading upon installation read 0 gallons. The total volume discharged for June 2008 was based on combined readings from both the old and replacement meters.

Please call if you have any questions regarding the above. We appreciate your continued assistance on the project.

Sincerely yours,
HALEY & ALDRICH, INC.

Sean D. Clifford
Staff Scientist

Joseph G. Savarese
Vice President

Enclosure

c: Hexcel Corporation; Attn: A. William Nosil

G:\Data\Hexcel\Permits\PVSC\DMR\July 2008 Hexcel Transmittal Letter.doc